

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014988.01  
DATE: 09/24/2020  
CERTIFICATION PROGRAM: Structural  
COMPANY: Starlink  
CODE: 2681-1

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Starlink Building Supply, Inc.</b> <b>4982 4th Street</b> <b>Irwindale, CA 91706</b>	<b>Glazed Inswing Fiberglass</b> <b>Side-Hinged Door Assembly</b>  Configuration: XX Glazing: Insulated Glass (Tempered) Frame: W-1816mm(71.5") H-2019mm(79.5") Panel: W-876mm(34.5") H-1956mm(77") DLO: W-530mm(20.88") H-1594mm(62.75")

SPECIFICATION	PRODUCT RATING
<b>AAMA 1702.2-95</b> <b>Federal Manufactured Home Construction</b> <b>&amp; Safety Standard 3280.305</b>	<b>Manufactured Housing-Passed</b> <b>Wind Zone I</b> <b>Design Wind Pressure Rating:</b> <b>+25/-12.5 psf</b>

Product Tested By: Testing Evaluation Laboratories, Inc.  
Report No: TEL 04602492  
Expiration Date: October 31, 2021

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122