## **NOTICE OF PRODUCT CERTIFICATION**



<b>CERTIFICATION NO:</b>
DATE:
<b>CERTIFICATION PROGRAM:</b>
COMPANY:
CODE:

NI014988.02	
09/24/2020	
Structural	
Starlink	
2681-1	

To verify that the "Notice of Product Certification" is valid, please visit <u>www.NAMICertification.com</u> to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION		
Starlink Building Supply, Inc.	<b>Opaque Inswing Fiberglass</b>		
4982 4th Street	Side-Hinged Door		
Irwindale, CA 91706			
	Configuration: X Glazing: Insulated Glass (Tempered)		
	Frame:	W-953mm(37.5")	H-2070mm(81.5")
	Panel:	W-908mm(35.75")	H-2010mm(79.13")

## SPECIFICATION

AAMA 1702.2-95 Federal Manufactured Home Construction & Safety Standard 3280.305

## **PRODUCT RATING**

Manufactured Housing-Passed Wind Zone III Design Wind Pressure Rating: +58/-58 psf

Product Tested By: Report No: Expiration Date: Testing Evaluation Laboratories, Inc. TEL 04602491 October 31, 2021

Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072 Tel: (804) 684-5124 Fax: (804) 684-5122