

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014988
DATE: 09/24/2020
CERTIFICATION PROGRAM: Structural
COMPANY: Starlink
CODE: 2681-1

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Starlink Building Supply, Inc. 4982 4th Street Irwindale, CA 91706	Glazed Inswing Fiberglass Side-Hinged Door Configuration: X Glazing: Insulated Glass (Tempered) Frame: W-946mm(37.25") H-2070mm(81.5") Panel: W-902mm(35.5") H-2007mm(79") DLO: W-530mm(20.88") H-1594mm(62.75")

SPECIFICATION	PRODUCT RATING
AAMA 1702.2-95 Federal Manufactured Home Construction & Safety Standard 3280.305	Manufactured Housing-Passed Wind Zone III Design Wind Pressure Rating: +58/-58 psf

Product Tested By: Testing Evaluation Laboratories, Inc.
Report No: TEL 04602490
Expiration Date: October 31, 2021

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122