

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI005905.01-R1  
**DATE:** 12/10/2004  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Window Crafts.  
**CODE:** 690-1  
**REVISION DATE:** 10/22/2020

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Window Craftsman</b> <b>6031 Clark Center Avenue</b> <b>Sarasota, FL 34238</b>	<b>Aluminum Fin Frame</b> <b>Horizontal Sliding Window</b>  Configuration: XX  Glazing: Insulating Glass (Annealed)  Frame: W-1829mm (72") H-1600mm (63") Panel: W-940mm (37") H-1549mm (61")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b> <b>AAMA/NWWDA 101/I.S.2-97</b>	<b>Class R-PG45 1829 x 1600 (72 x 63)-HS</b> <b>HS-R45</b> <b>Design Pressure: ±2155 Pa (45 psf)</b> <b>Water Penetration Resistance Test Pressure: 323 Pa (6.75 psf)</b>

Product Tested By: Certified Testing Laboratories  
Report No: CTLA-1245W/CTLA-1245W-1/W-1965  
Expiration Date: April 30, 2025

Administrator's Signature:  \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122