

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015002
DATE: 10/07/2020
CERTIFICATION PROGRAM: Structural
COMPANY: VK ECO Glass
CODE: 2291-1

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
VK ECO Glass, LLC dba Eco Glass 144 Hope Street Longwood, FL 32750	Series "S-3720/3730" Vinyl Fixed Window Configuration: O Glazing: Insulating Glass (Annealed) Frame: W-1500mm(59.06") H-1800mm(70.87")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08	Class CW-PG100 1500 x 1800 (59 x 71)-FW Design Pressure: ±4800 Pa (±100 psf) Water Penetration Resistance Test Pressure: 730 Pa (15.0 psf) Canadian Air Infiltration/Exfiltration Level: Fixed

Product Tested By: AIR-INS inc.
Report No: AI-03642-A1 Rev. 1
Expiration Date: October 31, 2024

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "S. D.", written over a horizontal line.

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122