

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015022.02  
DATE: 10/26/2020  
CERTIFICATION PROGRAM: Structural  
COMPANY: Dyke Ind.  
CODE: 2623-1

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	
<b>Dyke Industries</b> <b>653 Instrument Drive</b> <b>Rocky Mount, NC 27804</b>	<b>Plastpro Glazed Full Lite Inswing</b> <b>Fiberglass Double Door Assembly</b> <b>w/Sidelites</b>  Configuration: OXXO Glazing: Insulating Glass (Ext: Tempered/Int: Annealed)  Frame: W-3848mm(151.5") H-2073mm(81.63") Panel: W-908mm(35.75") H-2013mm(79.25")

SPECIFICATION	PRODUCT RATING
ASTM E283-04 ASTM E330-02 ASTM E331-02	Design Pressure: $\pm 2873$ Pa (60 psf) Water Penetration Resistance Test Pressure: 430 Pa (9.00 psf)

Product Tested By: Testing Evaluation Laboratories, Inc.  
Report No: TEL 01390244  
Expiration Date: **October 31, 2024**

Administrator's Signature:

  
**NATIONAL ACCREDITATION AND**  
**MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122