

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015023.01
DATE: 10/26/2020
CERTIFICATION PROGRAM: Structural
COMPANY: Dyke Ind.
CODE: 2623-1

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Dyke Industries 653 Instrument Drive Rocky Mount, NC 27804	Inswing Opaque Fiberglass Side Hinged Double Door Assembly Configuration: XX Frame: W-1885mm(74.21") H-2090mm(82.28") Panel: W-906mm(35.67") H-2017mm(79.41")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA 1304-02 A440S1-09	Class R-PG50 1885 x 2090 (74 x 82)-LW SHD Design Pressure: ± 2400 Pa (50 psf) Water Penetration Resistance Test Pressure: 0 Pa (0.00 psf) Forced Entry Resistance: Passed Canadian Air Infiltration/Exfiltration Level: A3

Product Tested By: Air-Ins, Inc.
Report No: AI-03950-J1
Expiration Date: October 31, 2024

A handwritten signature in black ink, appearing to be "S. D.", written over a horizontal line.

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Fax: (804) 684-5122