

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015030  
DATE: 10/26/2020  
CERTIFICATION PROGRAM: Structural  
COMPANY: Dyke Ind.  
CODE: 2623-1

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Dyke Industries 653 Instrument Drive Rocky Mount, NC 27804	Series "Rustic Mahogany" Opaque Inswing Fiberglass Side Hinged Door Assembly w/Fixed Sidelites & 2X Reinforcement Configuration: OXO Frame: W-1969mm(77.50") H-2489mm(98") Panel: W-1060mm(41.75") H-2419mm(95.25") DLO: W-178mm(7") H-2007mm(79")

SPECIFICATION	PRODUCT RATING
ASTM E283-04 ASTM E330-02 ASTM E331-00	Design Pressure: $\pm 2640$ Pa ( $\pm 55$ psf) Water Penetration Resistance Test Pressure: 0.0 Pa (0.0 psf)

Product Tested By: Testing Evaluation Laboratories, Inc.  
Report No: TEL 01391130  
Expiration Date: October 31, 2024

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122