

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015034  
DATE: 10/29/2020  
CERTIFICATION PROGRAM: Fire  
COMPANY: North State  
CODE: 2702-1  
EXPIRATION DATE: 10/31/2024

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>North State Millwork Corporation</b> <b>2708 West Raleigh Boulevard</b> <b>Rocky Mount, NC 27803</b>	<b>Jeld Wen 45-60 Minute</b> <b>Flush Core Side-Hinged Door</b>  Manufacturer Specific Fire Doors for Single & Double Swing Installation in 45-60 Minute Locations  1/2" Minimum Latch Throw Single & Double Swing Only  Single Maximum Size: 3'6" x 7'0" Single Maximum Size: 3'0" x 8'0" Double Maximum Size: 7'0" x 7'0" Double Maximum Size: 6'0" x 8'0" Minimum Thickness: 1-3/4"

SPECIFICATION	PRODUCT RATING
<b>UL 10(c) (2009/2016)</b> <b>CAN4 S104 (1985)</b> <b>CAN/ULC-S104 (2015)</b> <b>NFPA 252 (2012)</b>	<b>45-60 Minute-Positive Pressure w/Hose Stream</b> <b>Category A Door-No Additional Edge Seal</b> <b>Required</b> <b>For Use in 16 &amp; 18 Gauge Steel Frames</b> <small>(or may also be installed in Category C or Category C-Proprietary in accordance with individual manufacturer's listing)</small>

TEST REPORT
<b>Intertek Test Report No: G103003006MID-008, WHI-495-1607, J20017954-231, WHI-495-1456, G3043300, G3128474, G3186280, G3181954</b>

Administrator's Signature: 

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122