NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO:
DATE:
CERTIFICATION PROGRAM:
COMPANY:
CODE:
EXPIRATION DATE:

NI015035	
10/29/2020	
Fire	
North State	
2702-1	
10/31/2024	

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
North State Millwork Corporation	Jeld Wen 45-60 Minute
2708 West Raleigh Boulevard	Flush Core Side-Hinged Door
Rocky Mount, NC 27803	Manufacturer Specific Fire Doors for Single & Double Swing Installation in 45-60 Minute Locations
	1/2" Minimum Latch Throw Single & Double Swing Only
	Single Maximum Size: 3'6" x 7'0" Single Maximum Size: 3'0" x 8'0" Double Maximum Size: 7'0" x 7'0" Double Maximum Size: 6'0" x 8'0" Minimum Thickness: 1-3/4"

SPECIFICATION	PRODUCT RATING
UL 10(c) (2009/2016) CAN4 S104 (1985) CAN/ULC-S104 (2015) NFPA 252 (2012)	45-60 Minute-Positive Pressure w/Hose Stream Category B Door-Additional Edge Seal Required For Use in 16 & 18 Gauge Steel Frames (or may also be installed in Category C or Category C-Proprietary in accordance with individual manufacturer's listing)

TEST REPORT

Intertek Test Report No: G103003006MID-008, WHI-495-1607, J20017954-231, WHI-495-1456, G3043300, G3128474, G3186280, G3181954

Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072

> Tel: (804) 684-5124 Fax: (804) 684-5122