

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015037  
DATE: 10/29/2020  
CERTIFICATION PROGRAM: Fire  
COMPANY: North State  
CODE: 2702-1  
EXPIRATION DATE: 10/31/2024

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>North State Millwork Corporation</b> <b>2708 West Raleigh Boulevard</b> <b>Rocky Mount, NC 27803</b>	<b>Jeld Wen Premium 20 Minute Neutral Pressure Fiberglass Side-Hinged Door Assemblies</b>  Manufacturer Specific Fire Doors for Single Swing Installation in 20 Minute Locations  1/2" Minimum Latch Throw Single Swing and Pairs Allowed  <b>Single Swing Maximum Size: 3'0" x 8'0"</b> <b>Minimum Thickness: 1-3/4"</b>  <b>Pairs Maximum Size: 6'0" x 6'8"</b> <b>Minimum Thickness: 1-3/4"</b>

SPECIFICATION	PRODUCT RATING
<b>NFPA 252 (2008)</b> <b>UL 10B (2008/2009)</b> <b>CAN/ULC S104 (2010)</b>	<b>20 Minute-Neutral Pressure With Hose Stream</b> <b>Category B - Additional Edge Sealing Required</b>

TEST REPORT
<b>Intertek Test Report No: 3091617, 3145981MID-005b, 3153159MID-007, 100211525COQ-001</b>

Administrator's Signature: 

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Fax: (804) 684-5122