

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI015040  
**DATE:** 10/29/2020  
**CERTIFICATION PROGRAM:** Fire  
**COMPANY:** North State  
**CODE:** 2702-1  
**EXPIRATION DATE:** 10/31/2024

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>North State Millwork Corporation</b> <b>2708 West Raleigh Boulevard</b> <b>Rocky Mount, NC 27803</b>	<b>Endura 20 Minute Category C</b> <b>Proprietary Wood Door Frames</b>  Manufacture Specific Fire Door Frames for Single Swing Only Installation in 20 Minute Locations  <b>Single Door Maximum Size: 3'0" x 8'0"</b>  <b>Minimum Thickness: 4-9/16"</b>

SPECIFICATION	PRODUCT RATING
<b>NFPA 252 (1995)</b> <b>UL 10b (1997)(2009)</b> <b>CAN/ULC S104 (1980)(2010)</b> <b>UBC Standard 7-2 (1994)</b>	<b>20 Minute-With Hose Stream</b> <b>Neutral Pressure</b> <b>Category C- Proprietary Frame</b>

TEST REPORT
<b>Intertek Test Report No(s): J98027188-231</b>

Administrator's Signature: \_\_\_\_\_ 

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122