

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015041
DATE: 10/29/2020
CERTIFICATION PROGRAM: Fire
COMPANY: North State
CODE: 2702-1
EXPIRATION DATE: 10/31/2024

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
North State Millwork Corporation 2708 West Raleigh Boulevard Rocky Mount, NC 27803	Endura 20 Minute Category C Proprietary Wood Door Frames Manufacture Specific Fire Door Frames for Double Swing Installation in 20 Minute Locations Single Door Maximum Size: 8'0" x 9'0" Minimum Jamb Depth: 3.5"

SPECIFICATION	PRODUCT RATING
NFPA 252 (2012) UL 10b (1997) UL 10c (2009) CAN/ULC S104 (2010) UBC Standard 7-2 (1994)	20 Minute-With Hose Stream Positive Pressure Category C- Proprietary Frame

TEST REPORT
Intertek Test Report No(s): 101305789COQ-002, 101664134COQ-002 Intertek Engineering Evaluation No(s): 102343380MID-001

A handwritten signature in black ink, appearing to be 'S.M.', written over a horizontal line.

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Fax: (804) 684-5122