

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015044  
DATE: 10/29/2020  
CERTIFICATION PROGRAM: Fire  
COMPANY: North State  
CODE: 2702-1  
EXPIRATION DATE: 10/31/2024

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>North State Millwork Corporation</b> <b>2708 West Raleigh Boulevard</b> <b>Rocky Mount, NC 27803</b>	<b>Taylor 90 Minute Steel</b> <b>Single Swing Side-Hinged Door</b> <b>w/Bayer Baytherm 3003 Core</b>  22 Gauge Steel Skin Door w/Bayer Baytherm 3003 Core for single swing installation in 90 Minute locations  1/2" Minimum Latch Throw Single Swing Only  <b>Maximum Size: 3'0" x 6'8"</b> <b>914mm x 2032mm</b>

SPECIFICATION	PRODUCT RATING
<b>NFPA 252 (2008)</b> <b>UL 10C (2009)</b> <b>CAN4 S104(1985)</b>	<b>90 Minute-Positive Pressure</b> <b>With Hose Stream</b> <b>Category B Door-Additional Edge Seal</b> <b>Required</b> <b>For Use in Category C Frame</b>

TEST REPORT
<b>Intertek Test Report No: 3193924MID-007</b>

Administrator's Signature:  \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122

