

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014981-R1
DATE: 09/23/2020
CERTIFICATION PROGRAM: Fire
COMPANY: Penrod
CODE: 2705-1
REVISION DATE: 10/22/2020
EXPIRATION DATE: 07/31/2024

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
The Penrod Company 272 Bendix Road, Suite 550 Virginia Beach, VA 23452	20 Minute Category C Proprietary PVC Door Frame Manufacture Specific Fire Door Frames for Single Swing Installation in 20 Minute Locations Single Door Maximum Size: 3'0" x 8'0" Minimum Throat Opening: 4.575"

SPECIFICATION	PRODUCT RATING
UL 10C (2016)	20 Minute-Without Hose Stream Positive Pressure Category C- Proprietary Frame

TEST REPORT
Intertek Test Report No(s): 104362363MID-004 Intertek Letter Report No: 104362363MID-010

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be 'S. D.', is written over the signature line.

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Fax: (804) 684-5122