

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI005821-R5
DATE: 10/15/2004
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1
REVISION DATE: 11/23/2020

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	Series "IWP 435" In-Swing Wood Radius Door w/Sidelights Configuration: O/X/O Glazing: Insulating Glass (Tempered) STP PSF Frame: W-6'1" Panel: W-3'0" Pos+90.0 H-8'7" W-7'0" Neg-97.5

SPECIFICATION	PRODUCT RATING
ASTM E283-04/E330-97/02/14	Design Pressure: +60/-65 psf

Product Tested By: Architectural Testing, Inc.
Report No: ATI-53075.01-301-47/W-1976
Installation Details: JW492004(1-5)
Expiration Date: **December 31, 2026**

A handwritten signature in black ink, appearing to be "S. D.", written over a horizontal line.

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124/ Fax: (804) 684-5122