

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014325-R1  
DATE: 01/22/2019  
CERTIFICATION PROGRAM: Structural  
COMPANY: Window Crafts  
CODE: 690-1  
REVISION DATE: 09/30/2020

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Window Craftsmen</b> <b>6031 Clark Center Avenue</b> <b>Sarasota, FL 34238</b>	<b>Series "A100"</b> <b>Vinyl Awning Window</b> <b>(New Construction or Replacement)</b>  Configuration: X Glazing: IG - 1/8" Annealed Glass/1/8" Annealed Glass/0.090" Solutia Saflex PVB Interlayer/1/8" Annealed Glass  Frame: W-1219mm(48") H-813mm(32") Vent: W-1168mm(46") H-762mm(30")

SPECIFICATION	PRODUCT RATING
ASTM E1886-05/13a ASTM E1996-06/14a	Design Pressure: $\pm 2400$ Pa (50 psf) Wind Zone 3 - Missile Level D

Product Tested By: Intertek, PLC  
Report No: 94289.03-501-47/W-1965  
Expiration Date: **January 31, 2026**

Administrator's Signature: 

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122