

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI004787-R7
DATE: 09/17/2001
CERTIFICATION PROGRAM: Structural
COMPANY: West Window
CODE: 113-1
REVISION DATE: 09/07/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
West Window Corporation 226 Industrial Park Drive Martinsville, VA 24115	Series "Westview Vinyl Casement" Vinyl Casement Prime Window Configuration: X Glazing: Insulating Glass (Annealed) Frame: W-914mm(36") H-1829mm(72") Vent: W-889mm(35") H-1803mm(71")

SPECIFICATION	PRODUCT RATING
AAMA/NWWDA 101/I.S.2-97	C-LC50

Product Tested By: Architectural Testing, Inc.
Report No: ATI-07-30125.05
Expiration Date: **July 31, 2026**

A handwritten signature in black ink, appearing to be "S. D.", written over a horizontal line.

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com