

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI005080-R6
DATE: 05/02/2003
CERTIFICATION PROGRAM: Structural
COMPANY: West Window
CODE: 113-1
REVISION DATE: 05/17/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
West Window Corporation 226 Industrial Park Drive Martinsville, VA 24115	Series "Westco Picture Window" Aluminum Fixed Window Configuration: O Glazing: Insulating Glass (Annealed) Frame: W-1829mm(72") H-1829mm(72") Panel: W-1746mm(68.75") H-1746mm(68.75")

SPECIFICATION	PRODUCT RATING
AAMA/NWWDA 101/I.S.2-97 ASTM F588-97	F-HC85 1829 x 1829 (72 x 72) FER-Grade 10

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-8375-4
Expiration Date: **October 31, 2028**

Administrator's Signature: _____ 

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com