NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI005289-R12

DATE: 01/09/2004

CERTIFICATION PROGRAM: Structural

COMPANY: <u>Jeld-Wen</u>

CODE: 1822-1

REVISION DATE: 08/31/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Jeld-Wen Exterior Doors	Jeld-Wen's "Aurora" Composite
3737 Lakeport Boulevard	Double French Door with Side Lites
Klamath Falls, OR 97601	Configuration: OXXO
	Glazing: Insulating Glass (Tempered)
	Frame: W-2845mm(111.5") H-2438mm(97.75")
	Panel: W-965mm(38") H-2400mm(94.5")

SPECIFICATION	PRODUCT RATING
ASTM E331-00/E330-02/14	Design Pressure: +50/-50

Product Tested By: Architectural Testing, Inc.

Report No: 03-31287.01/W-1976/W-2004/W-2078

Installation Details: JW332004HOPPE(1-6)

Expiration Date: April 30, 2025

Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072 Tel: (804) 684-5124

nami@namiinc.com