

# NOTICE OF PRODUCT CERTIFICATION



**Company:** Therma-Tru Corporation  
 108 Mutzfeld Road  
 Butler, IN 46721

**Certification No.:** NI005327-R7  
**Certification Date:** 10/15/2003  
**Expiration Date:** 12/31/2031  
**Revision Date:** 01/10/2022

**Product:** FiberClassic/Smooth Star Glazed Fiberglass Door Inswing/Outswing w/ and w/o Sidelites  
**Benchmark by Therma-Tru Series Glazed Fiberglass Door Inswing/Outswing w/ and w/o Sidelites**  
**Specification:** ASTM E330

The "Notice of Product Certification" is only valid if the NAMI Certification Label has been applied to the product as described within this document. The certification label represents product conformity to the applicable specification and that all certification criteria has been satisfied. This product has been approved for listing within NAMI's Certified Product Listing at [www.Namicertification.com](http://www.Namicertification.com). NAMI's Certification Program is accredited by The American National Standards Institute (ANSI).

Configuration	Inswing or Outswing	Glazed or Opaque	Maximum Size	Design Pressure Pos/Neg	Missile Impact Rated	Test Report Number & Comments
X Single	I/S	Glazed	3'0" x 8'0"	+47/-47	No	NCTL-210-1940-1.2.3.4/TTF-257F
X Single	O/S	Glazed	3'0" x 8'0"	+47/-47	No	NCTL-210-1940-1.2.3.4/TTF-257F
XX Double	I/S	Glazed	6'0" x 8'0"	+40/-40	No	NCTL-210-1940-1.2.3.4/TTF-257F Standard Aluminum Astragal
XX Double	O/S	Glazed	6'0" x 8'0"	+40/-40	No	NCTL-210-1940-1.2.3.4/TTF-257F Standard Aluminum Astragal
XX Double	I/S	Glazed	6'0" x 8'0"	+47/-47	No	NCTL-210-1940-1.2.3.4/TTF-257F Coastal Aluminum Astragal
XX Double	O/S	Glazed	6'0" x 8'0"	+47/-47	No	NCTL-210-1940-1.2.3.4/TTF-257F Coastal Aluminum Astragal
OXO/OX/XO Single w/Sidelites	I/S	Glazed Door Glazed Sidelites	5'4" x 8'0"	+40/-40	No	ETC-01-741-10593.0/L-2173/TTF-257F
OXO/OX/XO Single w/Sidelites	O/S	Glazed Door Glazed Sidelites	5'4" x 8'0"	+40/-40	No	ETC-01-741-10593.0/L-2173/TTF-257F
OXXO Double w/Sidelites	I/S	Glazed Door Glazed Sidelites	8'4" x 8'0"	+40/-40	No	ETC-01-741-10593.0/L-2173/TTF-257F Standard Aluminum Astragal
OXXO Double w/Sidelites	O/S	Glazed Door Glazed Sidelites	8'4" x 8'0"	+40/-40	No	ETC-01-741-10593.0/L-2173/TTF-257F Standard Aluminum Astragal
OXXO Double w/Sidelites	I/S	Glazed Door Glazed Sidelites	8'4" x 8'0"	+47/-47	No	ETC-01-741-10593.0/L-2173/TTF-257F Coastal Aluminum Astragal
OXXO Double w/Sidelites	O/S	Glazed Door Glazed Sidelites	8'4" x 8'0"	+47/-47	No	ETC-01-741-10593.0/L-2173/TTF-257F Coastal Aluminum Astragal

National Accreditation & Management Institute, Inc./4794 George Washington Memorial Highway/Hayes, VA 23072

Tel: (804) 684-5124/Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NAMI AUTHORIZED SIGNATURE: \_\_\_\_\_

A handwritten signature in black ink, appearing to be 'S.M.', is written over a horizontal line that serves as the signature line.