

NOTICE OF PRODUCT CERTIFICATION



Company: Therma-Tru Corporation
 108 Mutzfeld Road
 Butler, IN 46721

Certification No.: NI005330-R6
Certification Date: 10/15/2003
Expiration Date: 12/31/2031
Revision Date: 08/23/2022

Product: FiberClassic/Smooth Star Glazed Fiberglass Door Inswing/Outswing w/ and w/o Sidelites
Benchmark by Therma-Tru Series Glazed Fiberglass Door Inswing/Outswing w/ and w/o Sidelites
Specification: ASTM E330/E331/TAS202

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

Configuration	Inswing or Outswing	Glazed or Opaque	Maximum Size	Design Pressure Pos/Neg	Missile Impact Rated	Test Report Number & Comments
X Single	I/S	Glazed	3'0" x 6'8"	+47/-47	No	NCTL-210-1940-1.2.3.4/TTF-256F
X Single	O/S	Glazed	3'0" x 6'8"	+47/-47	No	NCTL-210-1940-1.2.3.4/TTF-255F
XX Double	I/S	Glazed	6'0" x 6'8"	+40/-40	No	NCTL-210-1940-1.2.3.4/TTF-256F Standard Aluminum Astragal
XX Double	O/S	Glazed	6'0" x 6'8"	+40/-40	No	NCTL-210-1940-1.2.3.4/TTF-255F Standard Aluminum Astragal
XX Double	I/S	Glazed	6'0" x 6'8"	+47/-47	No	NCTL-210-1940-1.2.3.4/TTF-256F Coastal Aluminum Astragal
XX Double	O/S	Glazed	6'0" x 6'8"	+47/-47	No	NCTL-210-1940-1.2.3.4/TTF-255F Coastal Aluminum Astragal
OXO/OX/XO Single w/Sidelites	I/S	Glazed Door Glazed Sidelites	5'4" x 6'8"	+40/-40	No	ETC-01-741-11008.0/L-2151/TTF-256F
OXO/OX/XO Single w/Sidelites	O/S	Glazed Door Glazed Sidelites	5'4" x 6'8"	+40/-40	No	ETC-01-741-11008.0/L-2151/TTF255F
OXXO Double w/Sidelites	I/S	Glazed Door Glazed Sidelites	8'4" x 6'8"	+40/-40	No	ETC-01-741-11008.0/L-2151/TTF-256F Standard Aluminum Astragal
OXXO Double w/Sidelites	O/S	Glazed Door Glazed Sidelites	8'4" x 6'8"	+40/-40	No	ETC-01-741-11008.0/L-2151/TTF255F Standard Aluminum Astragal
OXXO Double w/Sidelites	I/S	Glazed Door Glazed Sidelites	8'4" x 6'8"	+47/-47	No	ETC-01-741-11008.0/L-2151/TTF-256F Coastal Aluminum Astragal
OXXO Double w/Sidelites	O/S	Glazed Door Glazed Sidelites	8'4" x 6'8"	+47/-47	No	ETC-01-741-11008.0/L-2151/TTF255F Coastal Aluminum Astragal

National Accreditation & Management Institute, Inc./4794 George Washington Memorial Highway/Hayes, VA 23072
Tel: (804) 684-5124/nami@namiinc.com

NAMI AUTHORIZED SIGNATURE: _____

A handwritten signature in black ink, appearing to be 'S.M.', is written over a horizontal line.