

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI005337.01-R9
DATE: 08/09/2010
CERTIFICATION PROGRAM: Structural
COMPANY: Natural Light
CODE: 557-1
REVISION DATE: 01/23/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|--|--|
| Natural Light Energy Systems 10821 North 23rd Avenue, #1 Phoenix, AZ 85029 | Model " Natural Light/SolarSkyLite 10" Single Glazed, Pitched, Self-Flashing Tubular Skylight Dome: 0.177" Optix Acrylic Plastic |

| SPECIFICATION | PRODUCT RATING |
|---|---|
| ASTM E330-97/TAS 201/202/203-94 ASTM E1886/E1996 ASTM E331-00/283-99 | Design Pressure: ±80 psf Missile Impact Rated-Passed as Stated |

Product Tested By: Hurricane Testing Laboratory, Inc.
Report No: 0290-0318-02 (Specimen #4 A-C)/W-1457
Expiration Date: **February 28, 2029**

Administrator's Signature: _____


**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com