NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO: DATE: CERTIFICATION PROGRAM: COMPANY: CODE: REVISION DATE:	<u>NI005846-R13</u> <u>10/15/2004</u> <u>Structural</u> <u>Jeld-Wen</u> <u>1822-1</u> 08/31/2023
REVISION DATE:	08/31/2023
	DATE: CERTIFICATION PROGRAM: COMPANY:

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit <u>www.namicertification.com</u>. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION	
Jeld-Wen Exterior Doors	Jeld-Wen's "Aurora" Double	
3737 Lakeport Boulevard	Out-Swing Opaque Fiberglass Door	
Klamath Falls, OR 97601	w/Pine or Polyurethane Frame or Aurora Composite Jamb w/min. 30lb/ft³ Density	
	Configuration: XX	
	Frame: W-2184mm(86") H-2464mm(97")	
	Panel: W-1067mm(42") H-2413mm(95")	

SPEC	IFICATION	PRODUCT RATING	
ASTM E1886-	330-02/14/E547 02/13a/E1996-02/14a /A 1304-02	Design Pressure: +50/-50 FER-Passed Missile Level D	
Product Tested By:			
Report No:	ATI-52734.01-301-44/52734.02-301-44/SJW2008-154/W-1407/ W-1894/W-1976/W-2004/W-2052/W-2078		
Expiration Date:	<u>March 31, 2026</u>		
Administrator's Signature:			
NATIONAL ACCREDITATION AND			
	MANAGEMENT	INSTITUTE, INC.	
	4794 George Washingt		
	Hayes, V Tel: (804)		

nami@namiinc.com