NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI005905.01-R2**
DATE:	**12/10/2004**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Window Crafts.**
CODE:	**690-1**
REVISION DATE:	**11/26/2024**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Window Craftsman **6031 Clark Center Avenue** **Sarasota, FL 34238**	**Aluminum Fin Frame** **Horizontal Sliding Window** Configuration: XX Glazing: Insulating Glass (Annealed) Frame: W-1829mm (72") H-1600mm (63") Panel: W-940mm (37") H-1549mm (61")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 **AAMA/WDMA/CSA 101/I.S.2/A440-08** **AAMA/NWWDA 101/I.S.2-97**	**Class R-PG45 1829 x 1600 (72 x 63)-HS** **HS-R45** **Design Pressure: ±2155 Pa (45 psf)** **Water Penetration Resistance Test Pressure: 323 Pa (6.75 psf)**

Product Tested By: Certified Testing Laboratories
Report No: CTLA-1245W/CTLA-1245W-1/W-1965
Expiration Date: **April 30, 2030**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com