

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI005973-R4  
DATE: 04/18/2005  
CERTIFICATION PROGRAM: Structural  
COMPANY: West Window  
CODE: 113-1  
REVISION DATE: 10/05/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>West Window Corporation</b> <b>226 Industrial Park Drive</b> <b>Martinsville, VA 24115</b>	<b>Model "Westco HS" Horizontal</b> <b>Sliding Aluminum Prime Window</b>  Configuration: XX Glazing: Insulating Glass (Annealed)  Frame: W-8'0"      H-5'4" Panel: W-4'1"      H-5'2"

SPECIFICATION	PRODUCT RATING
<b>ANSI/AAMA/NWWDA 101/I.S.2-97</b>	<b>HS-C30</b> <b>FER-Passed</b>

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-110-9556-1  
Expiration Date: February 28, 2028

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be "Shelby".

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Email: [nami@namiinc.com](mailto:nami@namiinc.com)