# NOTICE OF PRODUCT CERTIFICATION

| | |
|---|---|
| **CERTIFICATION NO:** | **NI006255-R14** |
| **DATE:** | **10/14/2005** |
| **CERTIFICATION PROGRAM:** | **Structural** |
| **COMPANY:** | **JELD-WEN** |
| **CODE:** | **1822-1** |
| **REVISION DATE:** | **07/21/2026** |

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|---|---|
| **JELD-WEN**<br>**3737 Lakeport Boulevard**<br>**Klamath Falls, OR 97601** | **"Contour Steel (S-2500) Wood Edge"**<br>**Double In-Swing/Out-Swing Steel Wood-Edge Entry Doors w/ODL Impact Glass or ODL Allen Frame and Endura Ultimate Hurricane Astragal**<br>Configuration: XX<br>Glazing: IG-1/8" Tempered Glass/ Laminate-1/8" Annealed Glass/0.090" Solutia Interlayer/1/8" Annealed Glass<br>Frame: W-1880mm(74") H-2108mm(83")<br>Panel: W-940mm(37") H-2007mm(79")<br>DLO: W-559mm(22") H-1626mm(64") |

| SPECIFICATION | PRODUCT RATING |
|---|---|
| **TAS 201/202/203-94** | **Design Pressure: +60/-60 psf**<br>**Large Missile Impact Rated** |

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-210-3195-1/SJW2011-070/W-1556/W-1565/W-1897/W-1905/W-2025/W-2039
Expiration Date: **September 30, 2030**

Administrator's Signature: _____


**NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.**
**4794 George Washington Memorial Highway**
**Hayes, VA 23072**
**Tel: (804) 684-5124**
**Email: nami@namiinc.com**