

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI006487-R8
DATE: 04/10/2006
CERTIFICATION PROGRAM: Structural
COMPANY: Nan Ya
CODE: 661-1
REVISION DATE: 01/16/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Nan Ya Plastics Corporation USA 8989 North Loop East, Suite 800 Houston, TX 77029	Series 9'0" x 8'0" Fiberglass In-Swing Glazed Double Door Configuration: XXX Glazing: IG-Laminate-1/8" Annealed Glass/0.090" PVB Interlayer/1/8" Annealed Glass/1/8" Tempered Glass Frame: W-9'3" Panel: W-3'0" DLO: W-1'9" H-8'0" H-8'0" H-6'7"

SPECIFICATION	PRODUCT RATING
AAMA/NWWDA 101/I.S.2-97 ASTM E330-02 AAMA 1302.5-76	HGD-LC25(w/water) Design Pressure: +50/-50 psf (w/o water) FER-Passed Qualifies Configurations: X, XX, XXX

Product Tested By: Certified Testing Laboratories
Report No: CTLA-1420W-1
Expiration Date: **February 28, 2036**

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023