

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI006822-R7  
DATE: 11/16/2006  
CERTIFICATION PROGRAM: Structural  
COMPANY: Carriage House  
CODE: 1008-1  
REVISION DATE: 08/16/2022

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Carriage House Door Company</b> <b>1571 East Main Street</b> <b>Old Fort, NC 28762</b>	<b>Model "202" Wood</b> <b>Garage Door</b>  Material: 1-3/8" Thick Wood Frame sheathed on Interior by 1/4" Exterior Plywood/Exterior-1/2" Exterior Plywood w/1-1/4" Corrugated Box Nails/Foam Insulating between plywood sheathing  Frame: W-4902mm(193") H-2438mm(96")

SPECIFICATION	PRODUCT RATING
<b>TAS 201/202/203-94</b> <b>ASTM E1996-02</b> <b>ASTM E330-02</b> <b>ANSI/DASMA 108-02/115-05</b>	<b>Design Pressure: 1915 Pa (40 psf)</b> <b>Negative Design Pressure: 2059 Pa (43 psf)</b> <b>Large Missile Impact Rated</b> <b>Missile Level D</b>

Product Tested By: American Test Lab, Inc.  
Report No: ATLNC 0814.01-06  
Expiration Date: **December 31, 2024**

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION &  
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)