

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI006832-R9
DATE: 11/17/2006
CERTIFICATION PROGRAM: Structural
COMPANY: Carriage House
CODE: 1008-1
REVISION DATE: 08/16/2022

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|---|--|
| Carriage House Door Company 1571 East Main Street Old Fort, NC 28762 | Model "101" Three-Section Wood Garage Door w/Two Non-Impact Windows Material: 1-3/8" Thick Wood Frame sheathed on Interior by 1/4" Exterior Plywood/Exterior-1/2" Exterior Plywood w/1-1/4" Corrugated Box Nails/Foam Insulating between plywood sheathing Glazing: 1/8" Annealed Glass (Non-Impact) Windows: W-1251mm(49.25") H-610mm(24") Frame: W-3048mm(120") H-2438mm(96") |

| SPECIFICATION | PRODUCT RATING |
|--|---|
| TAS 202-94 ASTM E330-02 ANSI/DASMA 108-02 | Design Pressure: 1772 Pa (37 psf) Negative Design Pressure: 1772 Pa (37 psf) |

Product Tested By: American Test Lab, Inc.
Report No: ATLNC 1023.01-06
Expiration Date: December 31, 2024

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be 'S.M.', written over a horizontal line.

**NATIONAL ACCREDITATION &
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com