

NOTICE OF PRODUCT CERTIFICATION




CERTIFICATION NO: NI006929-R4
DATE: 02/21/2007
CERTIFICATION PROGRAM: Structural
COMPANY: Morgan Window
CODE: 808-1
REVISION DATE: 04/17/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Morgan Window & Glass, Inc. 207 Industrial Boulevard McRae, GA 31055	Series "M3100I" Aluminum Equal Leg Frame Impact Twin Mulled Fixed Window (w/Aluminum Fixed Panel) Configuration: OO/O Glazing: IG-1/8" Heat Strengthened Glass/0.100" Saflex HP PVB/1/8" Heat Strengthened Glass/3/16" Annealed Glass Frame: W-1854mm (73") H-2261mm (89") DLO: W-838mm (33") H-1676mm (66")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08 ANSI/AAMA/NWDA 101/I.S.2-97 ASTM E1886-02/13a ASTM E1996-02/12a	Class CW-PG60 1854 x 2261 (73 x 89)-FW F-HC60 Design Pressure: ±2873 Pa (60 psf) Water Penetration Resistance Test Pressure: 431 Pa (9.0 psf) Wind Zone 4 - Missile Level D

Product Tested By: Certified Testing Laboratories
Report No: CTLA 1633W/CTLA 1633W-1/CTLA 1473W-2/W-1967
Expiration Date: **February 28, 2026**

Administrator's Signature:  _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com