

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI007102.01-R5
DATE: 07/14/2006
CERTIFICATION PROGRAM: Structural
COMPANY: Caoba Doors
CODE: 588-1
REVISION DATE: 03/09/2021

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Caoba Doors 4918 Cedar Avenue Philadelphia, PA 19143	Series "2000" Side Load Double Hung Wood Window Configuration: X/X Glazing: 1/4" Tempered Glass Frame: W-1372mm(54") H-2527mm(99.5") Sash: W-1305mm(51.38") H-1264mm(49.75")

SPECIFICATION	PRODUCT RATING
AAMA/NWWDA 101/I.S.2-97 ASTM F588-04	H-C55 1372 x 2540 (54 x 100) Design Pressure: +55 psf Negative Design Pressure: -90 psf Water Resistance Test Pressure: 8.25 psf FER-Passed

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-9927-2
Expiration Date: March 31, 2027

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122