

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI008017-R4
DATE: 04/30/2007
CERTIFICATION PROGRAM: Structural
COMPANY: Quaker
CODE: 031-1
REVISION DATE: 09/16/2021

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Quaker Window Products Highway 63 South Freeburg, MO 65035	Series "V 200 Manchester PW" Vinyl Fixed Window Configuration: O Glazing: Insulating Glass (Annealed) Frame: W-1220mm(48") H-1220mm(48") DLO: W-1060mm(43") H-1054mm(43")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-05 ASTM F588-04	F-R35 1200 x 1200 (48 x 48) FER-Passed

Product Tested By: Architectural Testing, Inc.
Report No: 66486.01-801-47
Expiration Date: July 31, 2026

Administrator's Signature: _____ 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122