

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI008098.01-R7
DATE: 02/26/2008
CERTIFICATION PROGRAM: Structural
COMPANY: Ply Gem
CODE: 1408-1
REVISION DATE: 07/09/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Ply Gem Window Group 433 North Main Street Rocky Mount, VA 24151	Series "4701F" Aluminum Fixed Prime Window Configuration: O Glazing: Insulating Glass (Tempered) Frame: W-1829mm(72") H-2438mm(96") DLO: W-1727mm(68") H-2337mm(92")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-22 AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/NWWDA 101/I.S.2-97	Class R-PG50 1829 x 2438 (72 x 96)-FW F-R50 1829 x 2438 (72 x 96) Design Pressure: ±2400 Pa (±50 psf)

Product Tested By: National Certified Testing Laboratories, Inc.
Report No: NCTL-110-11150-1/W-1958/W-2047
Expiration Date: December 31, 2028

A handwritten signature in black ink, appearing to be "S. D.", written over a horizontal line.

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com