

NOTICE OF PRODUCT CERTIFICATION




CERTIFICATION NO: NI009012-R7
DATE: 09/27/2007
CERTIFICATION PROGRAM: Struct/Impact
COMPANY: Case Group
CODE: 1032-1
REVISION DATE: 08/18/2025

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
The Case Group, LLC 195 Cohoes Avenue Green Island, NY 12183	<p style="text-align: center;">Solid Wood Fixed Prime Window</p> <p style="text-align: center;">Configuration: O</p> <p style="text-align: center;">Glazing: IG-1/4" Annealed Glass/3/16" Heat Strengthened Glass/0.075" Vanceva Storm/3/16" Heat Strengthened Glass</p> <p>Frame: W-1908mm(75") H-2822mm (111")</p> <p>Vent: W-1748mm(68.8") H-2662mm (104.8")</p>

SPECIFICATION	PRODUCT RATING
<p style="text-align: center;">AAMA/WDMA/CSA 101/I.S.2/A440-05 ANSI/AAMA/WDMA 101/I.S.2/NAFS-02 ANSI/AAMA/NWDA 101/I.S.2-97 ASTM E1886-02/E1996-02 ASTM F588-04</p>	<p style="text-align: center;">FW-AW69 1908 x 2822 (75 x 111) Design Pressure: 3304 Pa (69 psf) Impact Rating: Design Pressure: +52/-69 psf Wind Zone 4-Missile Level D</p>

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-210-3336-1 (Structural/FER/Impact)
Expiration Date: September 30, 2026

Administrator's Signature: _____ 

**NATIONAL ACCREDITATION AND
 MANAGEMENT INSTITUTE, INC.**
 4794 George Washington Memorial Highway
 Hayes, VA 23072
 Tel: (804) 684-5124
 Email: nami@namiinc.com