

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI009099-R3  
DATE: 09/12/2007  
CERTIFICATION PROGRAM: Structural  
COMPANY: Simpson  
CODE: 1145-1  
REVISION DATE: 01/31/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Simpson Door Company</b> <b>400 Simpson Avenue</b> <b>McCleary, WA 98557</b>	<b>Series "7001" Wood</b> <b>French Fixed</b>  Configuration: O Glazing: IG-1/8" Tempered Glass/Laminate- 1/8" Annealed Glass/0.090" DuPont Sentryglas®Plus/ 1/8" Annealed Glass  Frame: W-940mm(37") H-2489mm(98") Panel: W-914mm(36") H-2438mm(96")

SPECIFICATION	PRODUCT RATING
<b>ASTM E330-02/E283-04/E547-00</b> <b>ASTM E1886-04/E1996-03</b>	<b>Design Pressure: ±2873 Pa (60 psf)</b> <b>Wind Zone 4-Missile Level D</b>

Product Tested By: Construction Consulting Laboratory, International  
Report No: CCLI-05-128/CCLI-07-136  
Expiration Date: April 30, 2031

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be "Shi", written over a horizontal line.

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)