NOTICE OF PRODUCT CERTIFICATION



This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit <u>www.namicertification.com.</u> NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION			
Maxim Industries, Inc.	Series "Dade Self-Flashing"			
201 Longhorn Road	Polycarbonate Glazed Aluminum Skylight			
Fort Worth, Texas 76179				
	Configuration: O			
	Glazing: Exterior Dome-0.118" Hyzod Polycarbonate w/8" rise/Interior Dome-0.118" Hyzod Polycarbonate w/4" rise			
	Overall:	W-4'6"	DLO:	W-3'9"
		H-8'6"		H-7'9"

SPECIFICATION	PRODUCT RATING	
TAS 201/202/203-94	Design Pressure: +60/-60 psf Large Missile Impact Rated	

Product Tested By:Architectural Testing, Inc.Report No:ATI-01-43381.01Expiration Date:December 31, 2024

Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC. 4794 George Washington Memorial Highway Hayes, VA 23072 Tel: (804) 684-5124 Email: nami@namiinc.com