

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI009388.01-R10
DATE: 03/15/2008
CERTIFICATION PROGRAM: Structural
COMPANY: Ply Gem
CODE: 1408-1
REVISION DATE: 01/02/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Ply Gem Window Group 433 North Main Street Rocky Mount, VA 24151	Series “Classic Vinyl Double Hung w/o Sill Riser” Vinyl Double Hung Prime Window Configuration: X/X Two Locks-No Reinforcement in Stiles Glazing: Insulating Glass (Annealed) Frame: W-901mm(36") H-1562mm(62") Sash: W-822mm(32.37") H-767mm(30.18")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-05	Class R-PG20 901 x 1562* (36 x 62*)-H H-R20 901 x 1562 (36 x 62) Positive Design Pressure: 2394 Pa (50 psf) Negative Design Pressure: 2394 Pa (50 psf) Water Penetration Resistance Test Pressure: 144 Pa (3.0 psf)

Product Tested By: Certified Testing Laboratories
Report No: CTLA-989W-3/W-1493/W-1837/W-1889/W-1919/W-2047/W-2112
Expiration Date: **February 28, 2027**

Administrator's Signature: 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com