

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI009422.03-R4  
DATE: 04/10/2009  
CERTIFICATION PROGRAM: Structural  
COMPANY: Ply Gem  
CODE: 1408-1  
REVISION DATE: 09/05/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Ply Gem Window Group</b> 433 North Main Street Rocky Mount, VA 24151	<b>Series "4710F" Aluminum</b> <b>Single Hung Prime Window</b>  Configuration: O/X Glazing: Insulating Glass (Annealed)  Frame: W-1219mm(48") H-2134mm(84") Sash: W-1168mm(46") H-914mm(36")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-22 AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05	<b>Class R-PG 40 1219 x 2134 (48 x 84)-H</b> <b>H-R40 1219 x 2134 (48 x 84)</b> <b>Design Pressure: 1915 Pa (40 psf)</b> <b>Negative Design Pressure: 2873 Pa (60psf)</b>

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-110-12055-3/W-2047  
Expiration Date: March 31, 2029

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Email: [nami@namiinc.com](mailto:nami@namiinc.com)