NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI009499.03-R5**
DATE:	**05/20/2013**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Shwinco**
CODE:	**1972-1**
REVISION DATE:	**03/26/2026**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Shwinco Architectural Products, LLC **171 Jet Services Way** **Dothan, AL 36303**	**Series "9050" Impact Rated** **Vinyl Horizontal Sliding Window** Configuration: OX Glazing: IG-Exterior-3/16" Annealed Glass/ Laminate-1/8" Annealed Glass/0.090" Solutia Interlayer/1/8" Annealed Glass Frame: W-1372mm(54"") H-1524mm(60") Panel: W-689mm(27.13") H-1435mm(56.5")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 **AAMA/WDMA/CSA 101/I.S.2/A440-05** **ASTM E1886-02/05/13a/E1996-02/05/14a** **TAS 201/202/203-94**	**Class CW-PG70 1372 x 1524* (54 x 60*)-HS** **HS-C70 1372 x 1524 (54 x 60)** **Design Pressure: ±3352 Pa (70 psf)** **Wind Zone 4-Missile Level D** **Large Missile Impact Rated**

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-210-3529-1/210-3529-1A/W-1932
Expiration Date: **April 30, 2028**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com