

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI009646-R9
DATE: 10/02/2008
CERTIFICATION PROGRAM: Structural
COMPANY: New Erra
CODE: 1345-1
REVISION DATE: 09/18/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
New Erra Doors, LLC dba Custom Door & Millworks 2787 N. Airport Road, #410 Fort Myers, FL 33907	“Mara Macho” Mahogany Out-Swing Double Glazed Entry Door w/Arch Transom One Active Panel/One Inactive Panel w/Fixed Transom Configuration: O/XX Glazing: Monolithic Laminate - 1/4" Tempered Glass/ 0.100" Uvekol PVB Interlayer/1/4" Heat Strengthened Glass Frame: W-6'3" H-13'4" Panel: W-3'0" H-10'0" Transom: W-6'3" H-3'2"

SPECIFICATION	PRODUCT RATING
ASTM E283-04/E330-02/E547-00 ASTM E1886-05/E1996-05	Design Pressure: +55/-55 psf Wind Zone 4 - Missile Level D

Product Tested By: Certified Testing Laboratories
Report No: CTLA-1850W-1
Expiration Date: September 30, 2024

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com