

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI009727.01-R7  
**DATE:** 12/19/2008  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Glass Craft  
**CODE:** 1157-1  
**REVISION DATE:** 12/20/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Glass Craft Door Corporation</b> <b>2002 Brittmoore</b> <b>Houston, TX 77043-2209</b>	<b>Series "Mahogany Entry Door"</b> <b>Double In-Swing &amp; Out-Swing TDL Door</b> <b>w/Half Circle TDL Transom</b>  Configuration: Transom over One Active & One In-Active Panel  Glazing: Insulating Glass (Tempered)  Frame: W-1880mm(74") H-3505mm(138") Panel: W-914mm(36") H-2438mm(96")

SPECIFICATION	PRODUCT RATING
<b>ASTM E330/E330M-14</b>	<b>Design Pressure: +44.24/-55.72 psf</b> <b>Qualifies Configurations: X/XX/O/X/O/XX</b>

Product Tested By: Architectural Testing Incorporated  
Report No: ATI-81838.01-801-44/ATI-81839.01-801-44/W-2108  
Expiration Date: April 30, 2025

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)