NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI009810.03-R2**
DATE:	**02/04/2009**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Ply Gem**
CODE:	**1408-1**
REVISION DATE:	**04/06/2026**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Ply Gem Window Group **433 North Main Street** **Rocky Mount, VA 24151**	**Series "GLW-CPPD-101"** **Vinyl Sliding Glass Door** Configuration: XO Glazing: Insulating Glass (Tempered) Frame: W-1800mm(70.88") H-2070mm(81.50") Panel: W-922mm(36.32") H-1988mm(78.25")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08 **AAMA/WDMA/CSA 101/I.S.2/A440-05** **ANSI/AAMA/NWWDA 101/I.S.2-97**	**Class R-PG50 1800 x 2070 (71 x 82)-SD** **SD-R50 1800 x 2070 (71 x 82)** **SGD-R50** **Design Pressure: 2400 Pa (50 psf)** **Negative Design Pressure: 2880 Pa (60 psf)** **Water Penetration Resistance Test Pressure: 360 Pa (7.50 psf)**

Product Tested By: ETC Laboratories
Report No: ETC 08-552-21282.0
Expiration Date: **July 31, 2030**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com