

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI009825.02-R4  
DATE: 01/19/2010  
CERTIFICATION PROGRAM: Structural  
COMPANY: Ply Gem  
CODE: 1408-1  
REVISION DATE: 09/05/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Ply Gem Window Group</b> <b>433 North Main Street</b> <b>Rocky Mount, VA 24151</b>	<b>Series "700"</b> <b>Vinyl Fixed Window</b>  Configuration: O Glazing: Insulating Glass (Annealed)  Frame: W-2159mm(85.00") H-2159mm(85.00") STP: Pos+2160 Pa(45.0 psf) Neg-2160 Pa(45.0psf)

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-22</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-05</b>	<b>Class CW-PG30 2159 x 2159 (85 x 85)-FW</b> <b>FW-C30 2159 x 2159 (85 x 85)</b>

Product Tested By: Quality Testing, Inc.  
Report No: NS2010-015/W-2047  
Expiration Date: **January 31, 2029**

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be "Shelby".

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)