

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI010036-R4
DATE: 10/19/2009
CERTIFICATION PROGRAM: Structural
COMPANY: American
CODE: 1582-1
REVISION DATE: 06/07/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
American Skylites 525 113th Street Arlington, TX 76011	Series "CM-2" Aluminum Standard Curb Mount Plastic Dome Skylight Configuration: O Inner Dome: 0.177" Nominal Acrylic Outer Dome: 0.177" Nominal Acrylic Frame: W-2438mm (96.00") H-2438mm (96.00")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-05	SKP-C30 2438 x 2438 (96 x 96) Design Pressure (Download): 1440 Pa (30 psf) Negative Design Pressure (Uplift): 1440 Pa (30 psf) Water Penetration Resistance Test Pressure: 440 Pa (9.19 psf)

Product Tested By: Architectural Testing, Inc.
Report No: 92882.01-801-44
Expiration Date: **July 31, 2026**

Administrator's Signature:  _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com