NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO: NI010037.01-R5
DATE: 10/19/2009
CERTIFICATION PROGRAM: Structural
COMPANY: American
CODE: 1582-1
REVISION DATE: 02/17/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
American Skylites **525 113th Street** **Arlington, TX 76011**	**Series "TCM-2" Thermally-Broken Aluminum Curb Mount Plastic Dome Skylight** Configuration: O Inner Dome: 0.118" Nominal Acrylic Outer Dome: 0.177" Nominal Acrylic Frame: W-1524mm(60") H-2438mm(96")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-05	**SKP-C60 1524 x 2438 (60 x 96)** **Design Pressure (Download): 2880 Pa (60 psf)** **Negative Design Pressure (Uplift): 2880 Pa (60 psf)** **Water Resistance Test Pressure: 440 Pa (9.19 psf)**

Product Tested By: Architectural Testing, Inc.
Report No: 92883.02-801-44
Expiration Date: **August 31, 2029**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com