

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI010113.01-R7  
**DATE:** 02/10/2010  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Sun-Tek  
**CODE:** 225-1  
**REVISION DATE:** 09/15/2025

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Sun-Tek Manufacturing, Inc.</b> <b>10303 General Drive</b> <b>Orlando, FL 32824</b>	<b>Series "CMA 4646" Curb Mounted</b> <b>Aluminum Polycarbonate Dome Skylight</b> <b>with Deco Ring</b> <b>Configuration: O</b>  Polycarbonate: Outer Dome: 0.060" Flat Liner: 0.030"  Frame: W-1286mm(50.62") H-1286mm(50.62")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-05</b>	<b>Class CW-PG60 1286 x 1286 (51 x 51)-RWP</b> <b>Class CW-PG60 1286 x 1286 (51 x 51)-SKP-RW</b> <b>SKP/RW-C60 1286 x 1286 (51 x 51)</b>

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-210-3647-4/W-1969  
Expiration Date: **October 31, 2027**

Administrator's Signature:  \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023