NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI010128-R3**
DATE:	**02/28/2010**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Therma-Tru**
CODE:	**052-1**
REVISION DATE:	**03/23/2026**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Therma-Tru Corporation **118 Industrial Drive** **Edgerton, OH 43517**	**Series "ClassicCraft"** **Opaque Fiberglass In-Swing & Out-Swing** **Side Hinged Door** Door Panel: Fiberglass Configuration: X Frame: W-959mm(37.75") H-2089mm(82.25") Panel: W-913mm(35.93") H-2013mm(79.25")

SPECIFICATION	PRODUCT RATING
TAS 201/202/203-94 **ASTM E330-02** **ASTM E1886-02/E1996-02**	**Design Pressure: +100/-100 psf** **Large Missile Impact Rated** **Wind Zone 4 - Missile Level D**

Product Tested By: Testing Evaluation Laboratories, Inc.
Report No: TEL-06-1031-1
Expiration Date: **March 31, 2036**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com