

NOTICE OF PRODUCT CERTIFICATION




CERTIFICATION NO: NI010263.01-R4
DATE: 09/30/2014
CERTIFICATION PROGRAM: Structural
COMPANY: TAPCO
CODE: 1247-1
REVISION DATE: 05/30/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
TAPCO, Inc. 1815 McCullough Boulevard Tupelo, MS 38801	Series "300-HV-F" Fixed Hurricane Screen Configuration: O Screen Material: 0.035" Stainless Steel Mesh Frame: W-2743mm (108.00") H-1295mm (51.00") Opening: W-2614mm (102.90") H-1166mm (45.90")

SPECIFICATION	PRODUCT RATING
TAS 201/202/203-94 ASTM E1886-02/05/E1996-02/05 ASTM-E330-02	Design Pressure: +70/-70 psf Wind Zone 4 - Missile Level E Large Missile Impact Rated

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-210-3737-1/NCTL-210-3657-1A/W-1720
Expiration Date: **January 31, 2026**

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com