

# NOTICE OF PRODUCT CERTIFICATION



**Company:** Wincore Window Company, LLC  
 250 Staunton Turnpike  
 Parkersburg, WV 26104

**Certification No.:** NI010278.02-R5  
**Certification Date:** 06/28/2010  
**Expiration Date:** 12/31/2028  
**Revision Date:** 02/20/2024

**Product:** Plastpro Fiberglass Side Hinged Door w/ or w/o Sidelites (w/Wood or Composite Frame)  
**Specification:** ASTM E283-04/E330-02/E547-00  
**Qualified Configurations:** O/X/OX/XO/OXO

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

Configuration	Inswing or Outswing	Glazed or Opaque	Maximum Size	Design Pressure Pos/Neg	Missile Impact Rated	Test Report Number Drawing Number & Comments
OXO Single w/Sidelites	I/S	Glazed	9'4" x 6'10"	+40/-45	No	NCTL-110-12922-5/W-2040 Max Panel Size: 3'0" x 6'7" Max DLO: 1'9" x 5'3"/IG-1/8" Tempered Glass
OXO Single w/Sidelites	O/S	Glazed	9'4" x 6'10"	+45/-50	No	NCTL-110-12922-6/W-2040 Max Panel Size: 3'0" x 6'7" Max DLO: 1'9" x 5'3"/IG-1/8" Tempered Glass

**National Accreditation & Management Institute, Inc./4794 George Washington Memorial Highway/Hayes, VA 23072**  
**Tel: (804) 684-5124/nami@namiinc.com**

NAMI AUTHORIZED SIGNATURE: \_\_\_\_\_